

WELL CONSTRUCTOR'S REPORT

Well-6

WO# 9148

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPYSTATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1 COUNTY Ozaukee		CHECK ONE <input type="checkbox"/> Town <input type="checkbox"/> Village <input checked="" type="checkbox"/> City		NAME Cedarburg	
2 LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.) Lot 2, blk 2 Cedar Creek Heights 4928 Timbercrest Drive, NE 35 10N-21E					
3. OWNER AT TIME OF DRILLING Ernie Kamm					
4. OWNER'S COMPLETE MAIL ADDRESS 1016 Lakefield Road, Apt, 6, Grafton Wis. 53024					
5. Distance in feet from well to nearest: (Record answer in appropriate block)		BUILDING C. I.	SANITARY SEWER C. I.	FLOOR DRAIN C I	FOUNDATION DRAIN SEWER CONNECTED/INDEPENDENT
		15	45	45	15
CLEAR WATER DRAIN C. I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	WASTE WATER DRAIN C. I.
-	-	55	-	65	-
OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.) - above indicates NONE					

6. Well is intended to supply water for:

home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
7 7/8	Surface	42				sandy red clay & garvel	Surface	3
6	42	143				coarse gravel	3	10
8. CASING, LINER, CURBING, AND SCREEN						sandy red clay & gravel		
Dia. (in.)	Kind and Weight		From (ft.)	To (ft.)			10	18
6	std. steel P.E. Back new		Surface	42		yellow gumbo & loose lime	18	23
	18.97 lbs per foot					limestone	23	143
9. GROUT OR OTHER SEALING MATERIAL						RECEIVED SEP 08 1969 Dept. Nat. Res.		
Kind		From (ft.)	To (ft.)					
cement		Surface	42					
11. MISCELLANEOUS DATA						Well construction completed on Aug. 25 19 69		
Yield test:		1/2	Hrs. at	11	GPM	Well is terminated 8 inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade		
Depth from surface to normal water level		43	ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth to water level when pumping		60	ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Water sample sent to Madison						laboratory on: Aug. 25 19 69		

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Richard Berkholtz</i> Richard Berkholtz, Pres.		COMPLETE MAIL ADDRESS BERKHOLTZ DRILLING COMPANY INC. 1170 Forest Lane, Brookfield, Wis. 53005	
Registered Well Driller			

Please do not write in space below

COLIFOI	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
				